

Complete Fixture consists of Frame-In Kit and Reflector Trim. Select each separately.

Uniframe™ Compact Fluorescent Performance Series Reflector Trims		Compatible Uniframe™ Frame-In Kits (See Individual Frame-In Kit Specification Sheets)		
Catalog No.	Description	Catalog No.	Installation Type	Lamping
1013CFL	5" Vertical Open Downlight – Specular Clear	1001F13U	Non-IC 120/277v	13w Quad/Triple
1013CDCFL	5" Vertical Open Downlight – Clear Diffuse	1001F18U	Non-IC 120/277v	18w Triple
		1001FR18U	Non-IC Remodeler 120/277v	
		1001F18UEM	Non-IC Emergency 120/277v	
		1001F26U	Non-IC 120/277v	26w Triple
		1001FR26U	Non-IC Remodeler 120/277v	
		1001F26UEM	Non-IC Emergency 120/277v	
		1001FD26L1	Non-IC Lutron Dimming 120v	26w Triple
		1001FD26L2	Non-IC Lutron Dimming 277v	
		1001FD26MX1	Non-IC Advance Mark10 Dimming 120v	26w Triple
		1001FD26MX2	Non-IC Advance Mark10 Dimming 277v	
		1001FD26M7U	Non-IC Advance Mark7 Dimming 120/277v	

For other finishes please consult factory.

Features

- Reflector:** Formed aluminum. Matte White flange.
- Finishes:** CL = Specular Clear
CD = Clear Diffuse
- Performance Data:** 70° Cutoff angle.
See attached photometric reports for distribution and efficiency data.
Go to www.lightolier.com for .IES files.

Labels

cULus Listed. Suitable for Damp Locations. I.B.E.W.

Job Information	Type:
Job Name:	
Cat. No.:	
Lamp(s):	
Notes:	


631 Airport Road, Fall River, MA 02720 • (508) 679-8131 • Fax (508) 674-4710
 We reserve the right to change details of design, materials and finish.
www.lightolier.com © 2008 Philips Group • 0408

26W Sylvania Dulux T/E Triple Tube. Lumen Rating = 1800 LMS. Specular Clear Trim

Zonal Lumens and Percentages

Zone	Lumens	% Lamp	%luminaire
0-30	294	16.35	34.91
0-40	501	27.86	59.47
0-60	825	45.89	97.96
0-90	843	46.84	100.00
40-90	341	18.99	40.53
60-90	17	.96	2.04
90-180	0	0.00	0.00
0-180	843	46.84	100.00

** Efficiency = 46.8% **



SC = 1.3

Certified Test Report No. 3724FR
Computed by LSI Program
Test-Lite

Candlepower Summary

Angle	Mean Cp	Lumens
0	284	
5	302	29
10	320	
15	325	94
20	362	
25	377	171
30	363	
35	330	207
40	296	
45	273	208
50	231	
55	121	117
60	47	
65	9	16
70	1	
75	0	1
80	0	
85	0	0
90	0	

Coefficients of Utilization

CC	80				70				50				30				10				0
	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	
Wall	Zonal Cavity Method - Effective Floor Cavity Reflectance = .20																				
RCR	Zonal Cavity Method - Effective Floor Cavity Reflectance = .20																				
0	.56	.56	.56	.56	.54	.54	.54	.54	.52	.52	.52	.50	.50	.50	.48	.48	.48	.47	.47	.47	
1	.53	.51	.50	.49	.52	.50	.49	.48	.48	.47	.46	.46	.46	.45	.45	.44	.44	.43	.43	.43	
2	.49	.47	.45	.43	.48	.46	.44	.42	.44	.43	.41	.43	.42	.40	.42	.41	.40	.39	.39	.39	
3	.46	.43	.40	.38	.45	.42	.39	.37	.41	.38	.37	.39	.38	.36	.38	.37	.36	.35	.35	.35	
4	.43	.39	.36	.33	.42	.38	.36	.33	.37	.35	.33	.36	.34	.32	.35	.34	.32	.31	.31	.31	
5	.40	.35	.32	.30	.39	.35	.32	.29	.34	.31	.29	.33	.31	.29	.32	.30	.29	.28	.28	.28	
6	.37	.32	.29	.26	.36	.32	.28	.26	.31	.28	.26	.30	.27	.26	.29	.27	.25	.25	.25	.25	
7	.34	.29	.25	.23	.33	.28	.25	.23	.28	.25	.23	.27	.24	.22	.26	.24	.22	.21	.21	.21	
8	.32	.26	.22	.20	.31	.26	.22	.20	.25	.22	.20	.25	.22	.20	.24	.21	.20	.19	.19	.19	
9	.29	.24	.20	.18	.29	.23	.20	.18	.23	.20	.17	.22	.19	.17	.22	.19	.17	.16	.16	.16	
10	.27	.21	.18	.15	.26	.21	.18	.15	.20	.17	.15	.20	.17	.15	.20	.17	.15	.14	.14	.14	

Determined In Accordance with Current IES Published Procedures
Luminaire Input Watts = 29.0

Certified Test Report No. 3724FR
Computed by LSI Program **Test-Lite**

Lytecaster 6.75" Dia. Recessed Vertical Downlight
Cat. # RA-9743A (Elongated)
26W Sylvania Dulux T/E Triple Tube. Lumen Rating = 1800 LMS.
Universal Ballast #C2642UNVBES

IES Visual Comfort Probability

CC, WALL + FC Reflectance = 80, 50, 20
Work Plane Illuminance = 100.0 Footcandles
Work Plane Height = 2.5 Feet
All Dimensions In Feet

Room Dimensions		Luminaires Lengthwise				Luminaires Crosswise			
Height		8.5	10.0	13.0	16.0	8.5	10.0	13.0	16.0
W	L								
20	20	66	59	46	41	66	59	46	41
20	30	66	62	53	43	66	62	53	43
20	40	66	62	53	49	66	62	53	49
20	60	66	63	53	49	66	63	53	49
30	20	66	65	51	42	66	65	51	42
30	30	66	67	58	45	66	67	58	45
30	40	66	67	59	50	66	67	59	50
30	60	66	67	59	51	66	67	59	51
30	80	67	67	59	51	67	67	59	51
40	20	66	65	55	46	66	65	55	46
40	30	66	67	61	49	66	67	60	49
40	40	66	67	61	53	66	67	61	53
40	60	67	67	61	53	67	67	61	53
40	80	67	65	61	53	67	65	61	53
40	100	67	65	61	53	67	65	61	53
60	30	66	67	61	52	66	67	61	52
60	40	67	67	61	55	67	67	61	56
60	60	67	65	61	56	67	65	61	56
60	80	67	65	61	56	67	65	61	56
60	100	67	65	61	56	67	65	61	56
100	40	67	65	61	56	67	65	61	56
100	60	67	65	61	56	67	65	61	56
100	80	67	65	61	56	67	65	61	56
100	100	67	65	61	56	67	65	61	56

Job Information **Type:**

631 Airport Road, Fall River, MA 02720 • (508) 679-8131 • Fax (508) 674-4710
We reserve the right to change details of design, materials and finish.
www.lightolier.com © 2008 Philips Group • 0408